



Remedial Action List - September 2012

	Local Authority	Name of Water Supply	Scheme Code	Population Served	Volume Supplied	RAL Heading	Proposed Action Programme	Interim Measures	Proposed Date of Completion of Action Programme	Date Complete (if awaiting verification of the effectiveness)
1	Donegal County Council	Ballyshannon	0600PUB1105	5,000	1,573	Elevated levels of THMs above the standard in the Drinking Water Regulations	Operational improvements to include improved filter management	Turbidity monitors installed.	No date given	EPA Direction issued requiring works to be complete by 31/08/13
2	Donegal County Council	Burnfoot	0600PUB1026	1,000	178	Elevated levels of THMs above the standard in the Drinking Water Regulations	Abandon source and replace the supply with the Pollan Dam WS	Turbidity monitors installed	Jan-13	
3	Donegal County Council	Cashilard	0600PUB1106	400	284	Elevated levels of THMs above the standard in the Drinking Water Regulations	Abandon source and replace the supply with the Ballyshannon WS	To investigate interim groundwater source.		EPA Direction issued requiring works to be complete by 31/08/13
4	Donegal County Council	Creelough	0600PUB1075	4,000	2,035	Failed to meet E.coli/Enterococci standard as reported in the DW Report	Upgrade of disinfection system	N/A	No date given	
5	Donegal County Council	Donegal Eske	0600PUB1098	6000	2107	Excessive levels of aluminium in the treated water	Refurbishment of filters		Dec-12	
6	Donegal County Council	Fintown	0600PUB1065	310	331	Elevated levels of THMs above the standard in the Drinking Water Regulations	Upgrade of water treatment plant		No date given	EPA Direction issued requiring works to be complete by 31/08/13
7	Donegal County Council	Glenties-Ardara	0600PUB1070	4,500	1,555	Inadequate treatment for Cryptosporidium	Abandon source and replace with supply from the Leiternacaward WS	Cryptosporidium monitoring to determine risk	No date given	
8	Donegal County Council	Gortahork-Falcarragh	0600PUB1059	5,000	1,807	Excessive levels of aluminium in the treated water	Upgrade of Treatment Plant		No date given	EPA Direction issued requiring works to be complete by 30/06/13
9	Donegal County Council	Greencastle	0600PUB1015	807	480	Elevated levels of THMs above the standard in the Drinking Water Regulations	Abandon source and replace with supply from the East Inishowen WS		No date given	EPA Direction issued requiring works to be complete by 09/09/13
10	Donegal County Council	Owenteskna/Kilcar	0600PUB1091	300	262	Inadequate treatment for Cryptosporidium & THM's	Upgrade of Treatment Plant	N/A	Jun-13	
11	Donegal County Council	Letterkenny	0600PUB1110	19,500	8,855	Inadequate treatment for Cryptosporidium	Upgrade of Treatment Plant to include barrier for Cryptosporidium removal	N/A	No date given	EPA Direction issued requiring works to be complete by 31/08/13
12	Donegal County Council	Portnoo-Narin	0600PUB1068	656	118	Elevated levels of THMs above the standard in the Drinking Water Regulations			No date given	EPA Direction issued requiring works to be complete by 09/09/13
13	Donegal County Council	Rathmullen	0600PUB1053	2,050	641	Elevated levels of THMs above the standard in the Drinking Water Regulations			No date given	EPA Direction issued requiring works to be complete by 09/09/13
14	Donegal County Council	Rosbeg	0600PUB1067	285	66	Inadequate treatment for Cryptosporidium	Replace source of supply with the Portnoo WS	N/A	Nov-12	